

SOIL LOG

Job Number: 2025-TRK-005

Project Location: Rocky Point Phase 3, Lot 12
1486 N River Rock Circle

Logged By: Tom Klebesadel

Date: 3-11-25

TEST HOLE NO. 1

Depth (feet)	Description
0	Topsoil (OL)
1	
2	
3	
4	
5	
6	
7	
8	Well-graded sand (SW)
9	
10	
11	
12	
13	Bottom of test hole No groundwater
14	
15	
16	
17	
18	
19	
20	
21	



TEST HOLE LOCATION:

See test hole map

COMMENTS:

Soils can support a conventional onsite wastewater system. Soil rating estimated at 150 SF/BR if installed in SW layer.

This soil log was prepared for the sole purpose of determining the feasibility of constructing an onsite wastewater disposal system at the location of the test hole. Soil type ratings are based on visual observation and have not been verified with laboratory analyses. These soils have not been analyzed for structural stability or for any purpose other than wastewater absorption field construction. Anyone relying on this information for any use other than wastewater absorption field development shall do so at their own risk.



Matanuska-Susitna Borough



Legend

ParcelViewer

- Roads
 - Minor Road
- Mat-Su Borough Boundary
- Address Numbers
- Parcels
- ROW and Easements
 - ROW Road
- Section Lines

1 : 1128



THIS MAP IS NOT TO BE USED FOR NAVIGATION

0 50 100
ft

WGS_1984_Web_Mercator_Auxiliary_Sphere

Date: 03/17/25

This map is solely for informational purposes only. The Borough makes no express or implied warranties with respect to the character, function, or capabilities of the map or the suitability of the map for any particular purpose beyond those originally intended by the Borough. For information regarding the full disclaimer and policies related to acceptable uses of this map, please contact the Matanuska-Susitna Borough GIS Division at 907-861-7858.

Notes