

From: Extreme Heating & Air, Inc notifications@housecallpro.com  
Subject: Receipt from Extreme Heating & Air, Inc  
Date: Aug 7, 2026 at 11:55:15  
To: paul.l.douthit@gmail.com

---



## Your receipt from Extreme Heating & Air, Inc

**Job Number:** 94782  
**Service Date:** Aug 07, 2026  
**Customer Name:** Douthit, Paul  
**Service Address:** 16921 Foothill Ave Eagle River, AK 99577

| Services               | qty | amount   |
|------------------------|-----|----------|
| Preventive Maintenance | 1.0 | \$179.00 |

Minimum call fee for service tech on site.  
Any repairs or services provided past diagnostics will require customer approval.

|                              |     |         |
|------------------------------|-----|---------|
| Water Heater (Tanked system) | 1.0 | \$45.00 |
|------------------------------|-----|---------|

Water Heater: state select  
- Seismic Straps: tight  
- Expansion Tank: not on system  
- Ignition Type: spark natural gas pilot  
- Burners: bit of rust inside, cleaned  
- High Temp Limit:  
- Temp Setting: 140  
T&P and Drain: piped properly and sealed  
- Stand height and Pan: on Ground  
- Estimated Age of Unit: installed 8/07, 19 years  
Cycled, unit cycles normally

Notes: bit of rust inside, getting near the end of its life

\* Manufacture recommends annual preventive maintenance.  
Servicing equipment does not ensure future failure prevention.  
Customer approval is necessary for any required repairs, with  
materials used during service billed separately.  
Equipment recommendations will be provided by the technician.

|                        |             |                |
|------------------------|-------------|----------------|
| <b>Convenience Fee</b> | <b>0.03</b> | <b>\$10.37</b> |
|------------------------|-------------|----------------|

Credit Card Payment Fee (3%) Or Wisetack Financing Fee  
\*If paying by check or cash, please deduct this amount

|                            |            |                |
|----------------------------|------------|----------------|
| <b>PM - Unit Heater #1</b> | <b>1.0</b> | <b>\$45.00</b> |
|----------------------------|------------|----------------|

Unit Heater: Rennai  
- Ignition Type: spark  
- Heat Exchanger Condition: no visible cracks  
- CO Reading: 0 ppm  
- Burners: clean flames  
Cycled, cycles normally  
Notes: vacuumed filters

\* Manufacture recommends annual preventive maintenance.  
Servicing equipment does not ensure future failure prevention.  
Customer approval is necessary for any required repairs, with  
materials used during service billed separately.  
Equipment recommendations will be provided by the technician.

|                            |            |                |
|----------------------------|------------|----------------|
| <b>PM - Unit Heater #2</b> | <b>1.0</b> | <b>\$45.00</b> |
|----------------------------|------------|----------------|

Unit Heater: rennai  
- Ignition Type: spark  
- Heat Exchanger Condition: good no visible cracks  
- CO Reading: 0ppm  
- Burners: clean flames  
Cycled, normally  
Notes: vacuumed filters

\* Manufacture recommends annual preventive maintenance.  
Servicing equipment does not ensure future failure prevention.  
Customer approval is necessary for any required repairs, with  
materials used during service billed separately.  
Equipment recommendations will be provided by the technician.

|                            |            |                |
|----------------------------|------------|----------------|
| <b>PM - Unit Heater #3</b> | <b>1.0</b> | <b>\$45.00</b> |
|----------------------------|------------|----------------|

Unit Heater: rennai

- Ignition Type: spark  
- Heat Exchanger Condition: no visible cracks  
- CO Reading: 0ppm  
- Burners: clean blue flames  
Cycled, cycles normally  
Notes: vacuumed filters and cabinet

\* Manufacture recommends annual preventive maintenance.  
Servicing equipment does not ensure future failure prevention.  
Customer approval is necessary for any required repairs, with  
materials used during service billed separately.  
Equipment recommendations will be provided by the technician.

| Materials   | qty | amount    |
|-------------|-----|-----------|
| Consumables | 1.0 | \$5.00    |
| Subtotal    |     | \$374.37  |
| Military    |     | - \$18.72 |

|                  |                 |
|------------------|-----------------|
| Amount Paid      | <b>\$355.65</b> |
| Payment Method   | August 07, 2026 |
| mastercard x3246 | <u>11:55am</u>  |

[\(907\) 726-1805](tel:9077261805) | [ar@extremeheatingak.com](mailto:ar@extremeheatingak.com)

<http://extremeheatingak.com>

16805 Farm Ave  
EAGLE RIVER, AK 99577

[Terms & Conditions](#)