

Date 9/8/26

MOUNTAIN MECHANICAL CORP.

1300 Winners Circle Anchorage, AK 99518

PLUMBING & HEATING

344-0700

Future Appt. Date

Fax (907) 344-1937

PC-870

Email: info@mmalaska.com

License #29158

Name/ Billing SPRUE KERN

Address 6510 E. 16th

YP ☐ PC ☐ TV ☐ REF ☐

PHONE # _____

CELL #

EMAIL

10h01h ~~10h01h~~

Customer Problem

EST. TO REMOVE BECOM VINE ~~BEFORE~~ 8/210

[illegible]

Technician

Hrs

©

Total Labor

Material

03384I

Payment

TOTAL AMOUNT DUE	\$390
------------------------	-------

I HAVE THE AUTHORITY TO ORDER THE ABOVE WORK AND DO SO ORDER AS OUTLINED ABOVE. IT IS AGREED THAT THE SELLER RETAIN TITLE TO ANY EQUIPMENT OR MATERIAL FURNISHED UNTIL FINAL & COMPLETE PAYMENT IS MADE, AND IF SETTLEMENT IS NOT MADE AS AGREED, THE SELLER SHALL HAVE THE RIGHT TO REMOVE SAME AND THE SELLER WILL BE HELD HARMLESS FOR ANY DAMAGES RESULTING FROM THE REMOVAL THEREOF. FULL PAYMENT IS DUE UPON COMPLETION OF THE JOB UNLESS OTHER ARRANGEMENTS HAVE BEEN MADE. RETURN CHECKS WILL INCUR AN ADDITIONAL \$10.00 OFFICE CHARGE.

SIGN

A 90 day guarantee (except drain cleaning) is in effect for all labor and materials provided by this company. Some materials carry a separate manufacturer's warranty. We do not guarantee or install parts not supplied by our company. If repairs later become necessary due to other defective parts, they will be charged separately.

Records Only for Office Use

NAME: HELEN KLEIN DATE: 9/10/20
ADDRESS: 96510 E-16th #44/0401

1. Make LOCH Model WHN085 Ser # J11H30047024
2. Input 85/17K Output 79K Gas type NAT Gal 25+
3. Boiler pressure 20 Temp 100 Primary volts 120
4. Glycoled NO Aqua type CENT. Secondary CENT.
Inducer/Blower YES

GAS VALVE INFO MAKE/MODEL HW (100) Non 100%

5. Pilot Lit NO

6. Pilot ignition type SPARK 9.0 Burner comp OK

6. Pilot ignition type SPARK 9.0 Burner comp OK
7. Fill valve 1156 BFP CAL Tank Sz 30 Popoff WATTS

7. Fill valve 1156 BFP CAL Tank Sz 30 Popoff WATTS
8. Pump Type GRUND Pump cont NO Recir loop YES

9. Pump Amps 7 Aqua volts 24 Trans volts 24 / VA 56

10. Gas valve volts 24 Amps 4

11. Zone valve type HW Amps 1

	Wiring cond	Auto vents	#
12. Venting cond			

13. Leaks in system _____

14.	T-Stat make	Model	Setback
-----	-------------	-------	---------

15.	Contacts	Volts	H A	HA Condition
-----	----------	-------	-----	--------------

16. Zone Valves _____ Pump Amps _____

16. Zone valves _____ Pump Amps _____
17. GP# _____

[illegible]