

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

APPLICANT

WELL PERMIT NUMBER	<u>043591</u>	<u>F</u>
DIV. 2	CNTY. 14	WD 13
DES. BASIN		MD

Lot: 13 Block: Filing: 2 Subdiv: BLUMENAU

DOUG JONES
15 OAKBRIDGE DR
PUEBLO CO 81001

(719)544-7477

APPROVED WELL LOCATION
CUSTER COUNTY

SW 1/4 SE 1/4 Section 28
Twp 22 S RANGE 71 W 6th P.M.

DISTANCES FROM SECTION LINES

1000 Ft. from South Section Line
2400 Ft. from East Section Line

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of the permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction and Pump Installation Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 17.
- 3) Approved pursuant to CRS 37-90-137(2) on the condition that the well be operated in accordance with the Livingston Properties and Antelope Ranch Corp. Augmentation Plan approved by the Division 2 Water Court in case no. W-4062. If the well is not operated in accordance with the terms of said decree, it will be subject to administration including orders to cease diverting water.
- 4) Approved as the only well on a residential site of 6 acres described as lot 13, filing 2, Blumenau Subdivision, Custer County.
- 5) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling and shall not be used outside the house for any purpose.
- 6) The maximum pumping rate shall not exceed 15 GPM.
- 7) The annual amount of ground water to be withdrawn shall not exceed 1.0 acre-foot.
- 8) The return flow from the use of the well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 9) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 10) This well shall be constructed not more than 200 feet from the location specified on this permit.

5-26-94
APPROVED
HCF

Hal D. Simpson

State Engineer

Receipt No. 0367259

DATE ISSUED **MAY 27 1994**

[Signature]

By *[Signature]*
EXPIRATION DATE **MAY 27 1995**