

Private Well Replacement Construction Permit

November 6, 2023

Craig Brosius
2 Dunaway Dr.
Richmond, VA 23238

Tax Map # 54(7)5
HDID #: 166-23-237
Property Address:
End of Galway Drive on
Crank Island

The attached drawings and below specifications constitute your permit to install and abandon a private well on the property referenced above. This permit is null and void if conditions are changed from those shown on your application or if conditions are changed from those shown on the attached construction drawings and specifications. VDH may revoke or modify any permit if, at a later date, it finds that the site conditions, well location, and/or design do not substantially comply with the Private Well Regulations, 12 VAC 5-630-10 et seq, or if the well would threaten public health or the environment. There may be other local, state, or federal laws or regulations that apply to the proposed construction of this private well. The landowner is responsible at all times for complying with all applicable local, state, and federal laws and regulations, and for ensuring that the water well is properly located on the landowner's property and in the approved area indicated on the attached schematic.

Your private well must be inspected by a representative of the local health department. Your private well may not be placed into operation until you have obtained a Record of this Inspection (ROI) from the Northumberland County Health Department. This construction permit is transferable until expired or deemed null and void. A permit transfer form may be found on the VDH website at <http://www.vdh.virginia.gov/environmental-health/gmp-2015-01-forms/>.

Before you can obtain your ROI, you must provide the Health Department with a complete Water Well Completion Statement /GW-2 from your well driller and a record of a satisfactory bacteriological sample result.


Well Type: Domestic Drinking Well
Well Class: IIIB

Distance from Building Sewer: 50'+
Distance from Septic/Pretreatment Tank: 50'+
Distance from Conveyance System: 50'+
Distance from Absorption Area: 50'+
Minimum distance from any current or future soil-poisoned termite treated foundation: 50'+

Minimum Casing Depth: 50'
Minimum Grout Depth: 50'

Existing house is NOT termite treated.

THIS PERMIT EXPIRES: May 6, 2028

Issued by: 
Hank Becker,
Environmental Health Specialist, Sr.

Date: November 6, 2023

LOT 5

CRAIG BROSIUS
166-23-237
TM: 54(7)5
RE: WELL PERMIT

INSTALL:

NEW IIIB WELL
CASED 50'+
GROUTED 50'+
***KEEP NEW WELL 50'+ FROM ALL
SOURCES OF CONTAMINATION
***IF/ FOR QUESTIONS PLEASE CALL
NCHD (804)-580-3731

1" = 50'

