

JOSE RECEIVED

54373

JOSE 54373

STATE OF OREGON WATER SUPPLY WELL REPORT (as required by ORS 537.765)

NOV 19 2001

WATER RESOURCES DEPT. SALEM, OREGON

WELL I.D. # L 52124 START CARD # 144055

Instructions for completing this report are on the back of this form.

(1) LAND OWNER: MEL ATKINS, 980 SW 6TH SUITE 14, GRANTS PASS, OR 97526

(2) TYPE OF WORK: [X] New Well

(3) DRILL METHOD: [X] Rotary Air

(4) PROPOSED USE: [X] Domestic

(5) BORE HOLE CONSTRUCTION: Special Construction approval [] Yes [X] No Depth of Completed Well 160 ft.

Table with columns: HOLE, SEAL, Diameter, From, To, Material, Sacks or pounds. Includes entries for BENTONITE and CEMENT.

How was seal placed: Method [] A [] B [] C [] D [] E [X] Other DRY POUR/CEMENT CAP

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Includes entries for 6" casing and 4" liner.

Drive Shoe used [] Inside [X] Outside [] None Final location of shoe(s) 58'

(7) PERFORATIONS/SCREENS: [X] Perforations Method SAW

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Includes entry for slot size 6, number 48, diameter 1/4.

(8) WELL TESTS: Minimum testing time is 1 hour. Yield gal/min 20, Drawdown, Drill stem at 159, Time 1 hr.

Temperature of water 53 Depth Artesian Flow Found Was a water analysis done? [] Yes [] No

(9) LOCATION OF WELL by legal description: County JOSEPHINE, Township 37S, Section 11 SE 1/4 NW 1/4, Tax Lot 1500, Lot 7, Block, Subdivision, Street Address of Well STRINGER GAP

(10) STATIC WATER LEVEL: 18 ft. below land surface. Date 11-7-01

(11) WATER BEARING ZONES: Table with columns: From, To, Estimated Flow Rate, SWL. Includes entry for 60 to 140 ft depth.

(12) WELL LOG: Ground Elevation

Table with columns: Material, From, To, SWL. Includes entries for GRANITE DECOMP, GRANITE BLK & WHT SOFT, GRANITE BLK & WHT MEDIUM.

Date started 11/7/01 Completed 11/8/01

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards.

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above.