

Pam talked to WWS about why late.

RECEIVED

Jose 12028

375/6W-13

STATE OF OREGON WATER WELL REPORT OCT - 3 1985

PLEASE TYPE or PRINT IN INK

(for official use only)

WATER RESOURCES DEPT

(1) OWNER: SALEM, OREGON Name Ed Frank Address 318 Tribler Lane City Grants Pass State Ore

(2) TYPE OF WORK (check): New Well [x] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL: Rotary Air [x] Driven [] Rotary Mud [] Dug [] Bored [] (4) PROPOSED USE (check): Domestic [x] Industrial [] Municipal [] Thermal [] Withdrawal [] Reinjection [] Other: Piezometric [] Grounding [] Test []

(5) CASING INSTALLED: Steel [x] Plastic [] Threaded [] Welded [x] 6" Diam. from 12 ft. to 19 ft. Gauge 250

LINER INSTALLED: Steel [] Plastic [] Threaded [] Welded []

(6) PERFORATIONS: Perforated? [] Yes [x] No [] Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS: Well screen installed? [] Yes [x] No [] Manufacturer's Name Type Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No [] If yes, by whom? Air test 14 gal./min. with drill stem at 140 ft. 1 hrs. Bailer test Artesian flow 510 g.p.m. Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes [] No [x] Well seal—Material used cement grout Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Amount of sealing material 9 sacks [x] pounds [] How was cement grout placed? grout pump Was pump installed? 20 Type HP Depth ft. Was a drive shoe used? [x] Yes [] No [] Plugs Size: location ft. Did any strata contain unusable water? [] Yes [] No [] Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No [] Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description: County Josephine NW 1/4 SE 1/4 of Section 13 Township 37S Range 6W WM. Tax Loc 2707 Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address) same

(11) WATER LEVEL of COMPLETED WELL: Depth at which water was first found 135 ft. Static level 40 ft. below land surface. Date 8/26/85 Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6" Depth drilled 145 ft. Depth of completed well 145 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows: Granite soft (0-12), Granite med hard (12-30), Granite blk + white w/p (30-145), 145-40

Date work started 8/26/85 /completed 8/26/85 Date well drilling machine moved off of well 8/26 1985

(unbonded) Water Well Constructor Certification (if applicable): This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Date , 19

(bonded) Water Well Constructor Certification: Bond 28633211 Issued by: Western Surety (number) (Surety Company Name) On behalf of Applegate Well Drilling (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief: (Signed) Charles B. Pelley (Water Well Constructor) (Dated) 8/27/85

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP#46866-690