WATER WELL REPORT
STATE OF OREGON

RECEIVED
MAY 10 1982
WATER RESOURCES DEPT
SALEM, OREGON

KLAM 12321

State Well No. 38S/11E-15dda

State Permit No. .....

(1) OWNER:
Name Everett Wilson
Address Rt. 2 Box 75
City Bonanza State OR 97623

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:
Steel ☒ Plastic ☐
Threaded ☐ Welded ☒
6" Diam. from +1 ft. to 56 ft. Gauge .250
" Diam. from ..... ft. to ..... ft. Gauge .....

LINER INSTALLED:
" Diam. from ..... ft. to ..... ft. Gauge .....

(6) PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name .....
Type ..... Model No. .....
Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.
Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
[illegible]: gal./min. with ft. drawdown after hrs.
" " " "
Air test 20 gal./min. with drill stem at 310 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
[illegible]perature of water 56 Depth artesian flow encountered ..... ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No ☒
Well seal—Material used Cement
Well sealed from land surface to 50 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed? Pumped
Was pump installed? NO Type ..... HP ..... Depth ..... ft.
Was a drive shoe used? ☐ Yes ☒ No Plugs ----- Size: location ..... ft.
Did any strata contain unusable water? ☒ Yes ☐ No
Type of Water? Surface depth of strata 1' to 6'
Method of sealing strata off Casing & Cement
Was well gravel packed? ☐ Yes ☒ No Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

(10) LOCATION OF WELL:
County Klamath Driller's well number
NE ¼ SE ¼ Section 15 T. 38 S R. 11 E W.M.
Tax Lot # Lot 33 Blk 49 Subdivision K.F.F.E.
Address at well location:

(11) WATER LEVEL: Completed well.
Depth at which water was first found 300 ft.
Static level 300 ft. below land surface. Date 5-5-82
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 323 ft. Depth of completed well 314 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy Top Soil	0	4	
Yellow Clay	4	47	
Black Sandstone	47	56	
Black Lava Rock - Creviced	56	119	
Brown Lava Rock & Clay	119	140	
Black Lava Rock - Creviced	140	175	
Brown Lava Rock - Creviced	175	198	
Black Lava Rock - Creviced	198	225	
Brown Lava Rock - Creviced	225	250	
Black Lava Rock - Creviced	250	305	
Red Cinders	305	323	300'

Work started 5-4 1982 Completed 5-5 1982
Date well drilling machine moved off of well 5-5 1982

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Stephen R. Hughes (Drilling Machine Operator) Date 5-7, 1982
Drilling Machine Operator's License No. 1171

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Norm Sevey Well Drilling, Inc. (Person, firm or corporation) (Type or print)
Address 800 Old Midland Rd., Klamath Falls, OR 97601
[Signed] Norm Sevey (Water Well Contractor)
Contractor's License No. 408 Date 5-7, 19 82

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690