

# Well Flow Test



**Test ID:** 9232  
**Street Address:** 4784 FISH HATCHERY RD  
GRANTS PASS,OR 97527

**Test Date:** Aug 20,2024  
**Service Tech:** ELIJAH HARRIS  
**Name:** BUYER: SPENCER SMITH  
**Billing Address:** GRANTS PASS,OR 97527  
**Telephone:** 541.660.2311

**Test Requirements:** 4-HOUR OPEN FLOW

**Remarks:** SYSTEM WOULD NEED ELECTRICAL & PLUMBING FIXED BEFORE BEING USED.

**Equipment Used:** EXISTING PUMP SYSTEM 1/2HP  
**Source:** WELL  
**Well Depth:** N/A **Pumping Level:** N/A **Diameter:** 6  
**Water Color:** CLEAR **Odor:** NONE  
**Seal:** Yes **Vent:** Yes **Pop Off Valve:** No

## Flow Data:

Time	Flow	Level	Meter
02:00 PM	16.5 GPM	11 feet	247.50
02:15 PM	15 GPM	71 feet	472.50
02:30 PM	12 GPM	82 feet	652.50
02:45 PM	12 GPM	82 feet	832.50
03:00 PM	12 GPM	82 feet	1012.50
03:15 PM	12 GPM	82 feet	1192.50
03:30 PM	12 GPM	82 feet	1372.50
03:45 PM	12 GPM	82 feet	1552.50
04:00 PM	12 GPM	82 feet	1732.50
04:15 PM	12 GPM	82 feet	1912.50
04:30 PM	12 GPM	82 feet	2092.50
04:45 PM	12 GPM	82 feet	2272.50
05:00 PM	12 GPM	82 feet	2452.50
05:15 PM	12 GPM	82 feet	2632.50
05:30 PM	12 GPM	82 feet	2812.50
05:45 PM	12 GPM	82 feet	2992.50
06:00 PM	12 GPM	82 feet	3172.50