WATER WELL REPORT
STATE OF OREGON

Jose
10796

RECEIVED
NOV -4 1981
WATER RESOURCES DEPT
SALEM, OREGON

State Well No. 38/8W-2 26

State Permit No. .....

(1) OWNER:
Name Jim Roberts
Address 140 Draper Valley Rd.
City Selma State OR 97538

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air [X] Driven [ ]
Rotary Mud [ ] Dug [ ]
[redacted] [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]
Thermal: [ ] Withdrawal [ ] Reinjection [ ]

(5) CASING INSTALLED:
Steel [X] Plastic [ ]
Threaded [ ] Welded [X]
6" Diam. from 0 ft. to 40 ft. Gauge .250
" Diam. from ft. to ft. Gauge

[redacted] LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:
Perforated? [ ] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
[redacted]d: gal./min. with ft. drawdown after hrs.
" " " "
Air test 10 gal./min. with drill stem at 71 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
[redacted]esian flow g.p.m.
[redacted]perature of water 51° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes [ ] No [X]
Well seal—Material used Cement Grout
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? Grout Pump
Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Josephine Driller's well number 133
NW ¼ SE ¼ Section 2 T. 38 R. 8W W.M.
Tax Lot # 206 Lot Blk Subdivision
Address at well location: 140 Draper Valley Rd. Selma, Ore.

(11) WATER LEVEL: Completed well.
Depth at which water was first found 65 ft.
Static level 40 ft. below land surface. Date 10/29/81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 120 ft. Depth of completed well 120 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay	0	8	
Brown Shale	8	30	
Black Shale	30	45	
Black Shale w/Fract.	45	80	40
Gray Basalt w/Fract.	80	120	

Work started 10/29 1981 Completed 10/29 1981
Date well drilling machine moved off of well 10/29 1981

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert Monahan (Drilling Machine Operator) Date 10/30, 1981
Drilling Machine Operator's License No. 809

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name McCANAHAN WELL DRILLING (Person, firm or corporation) (Type or print)
Address 141 N.E. Beacon Dr. Grants Pass OR 97526
[Signed] Ken McCanahan (Water Well Contractor)
Contractor's License No. 727 Date 10/30, 1981

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690